

Отчет о потреблении тепловой энергии и теплоносителя за Январь 2016 г.

Потребитель: ООО УК "Уют плюс"

Адрес: Салиха Батыева 17

Договор: 12405

Тип прибора:

Номер прибора:

Теплосистема:

ТСРВ-020

1301801

1

Дата	W1, Гкал	m1, т	t1, °C	P1, МПа	W2, Гкал	m2, т	t2, °C	P2, МПа	W3, Гкал	m3, т	t3, °C	P3, МПа	W4, Гкал	m4, т	t4, °C	P4, МПа
01.01.16	38.299	369.873	103.93	0.79	19.793	367.599	53.68	0.49	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
02.01.16	40.340	388.692	104.12	0.80	21.094	386.432	54.47	0.48	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
03.01.16	38.341	369.718	104.08	0.83	19.664	367.395	53.30	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
04.01.16	38.189	369.379	103.78	0.82	19.395	366.910	52.60	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
05.01.16	34.954	337.875	103.85	0.85	17.342	335.680	51.54	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
06.01.16	35.079	346.722	101.64	0.82	17.584	344.503	50.82	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
07.01.16	35.466	355.649	100.08	0.84	18.078	353.445	51.00	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
08.01.16	33.163	348.141	95.70	0.84	16.899	346.051	48.75	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
09.01.16	29.119	317.831	92.05	0.85	14.613	315.908	46.17	0.44	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
10.01.16	26.458	289.536	91.69	0.86	12.910	287.636	44.70	0.43	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
11.01.16	31.657	328.400	96.35	0.83	15.842	326.373	47.92	0.45	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
12.01.16	43.323	430.160	101.06	0.79	23.532	427.732	54.86	0.49	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
13.01.16	35.493	365.467	97.43	0.84	18.533	363.344	50.82	0.46	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
14.01.16	29.725	334.972	89.03	0.82	15.437	333.066	46.21	0.46	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
15.01.16	28.360	316.290	89.85	0.85	14.394	314.405	45.49	0.46	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
16.01.16	38.540	401.549	96.22	0.80	20.608	399.386	51.37	0.48	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
17.01.16	38.007	399.384	95.55	0.80	20.298	397.141	51.03	0.48	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
18.01.16	27.129	310.909	87.77	0.85	13.886	308.990	44.80	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
19.01.16	29.473	342.506	86.27	0.81	15.708	340.361	45.90	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
20.01.16	27.444	312.129	88.27	0.87	14.161	310.183	45.50	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
21.01.16	29.765	333.110	89.41	0.86	15.428	331.168	46.25	0.47	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
22.01.16	34.540	359.416	96.45	0.86	18.026	357.263	50.25	0.48	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
23.01.16	30.757	338.188	91.47	0.87	15.876	336.109	47.18	0.46	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
24.01.16	36.303	381.857	94.99	0.81	19.234	379.365	50.19	0.48	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
25.01.16	43.838	422.674	103.97	0.81	23.723	420.318	56.30	0.49	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
26.01.16	46.608	440.866	106.06	0.81	25.468	438.320	57.98	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
27.01.16	45.917	434.186	106.15	0.82	24.825	431.418	57.42	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
28.01.16	40.451	383.339	105.92	0.86	20.981	380.823	54.94	0.49	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
29.01.16	31.915	310.639	103.01	0.87	14.852	308.479	47.70	0.46	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
30.01.16	24.526	266.168	92.38	0.88	10.540	264.300	39.58	0.45	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
31.01.16	22.171	274.056	81.33	0.84	10.046	272.295	37.09	0.46	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
Среднее:	34.366	354.183	96.77		17.702	352.013	49.54		0.000	0.000	0.00		0.000	0.000	0.00	
Итого:	1065.349	10979.683			548.771	10912.399			0.000	0.000			0.000	0.000		

Ответственный за учет тепловой энергии:

Отчет принят 200 г.

—

Дата и время	Wrt1 Intr. T _{can}	Mrt1 Intr. T _{can}	Wrt1 Intr. T _{can}
31.12.2015 23:59	5860.804	1049.415	0.000
31.01.2016 23:59	6377.382	1116.699	0.000

Отчет принят _____ 200 г.

www.vzljot.ru